


POWER GRID COMPANY OF BANGLADESH LIMITED

Southern Chattogram and Kaliakoir Transmission Infrastructure Development Project

Design, Supply, Installation, Testing & Commissioning of 230 kV and 132 kV Transmission Lines for Southern Area of Chattogram Division & Bangabandhu Hi-Tech City at Kaliakoir on Turnkey Basis (Package-2)
(IOCT No. PGCB/AIIB/000308-BGD/TL/Package-2)

CLARIFICATION NO. 3

Sl. No.	Reference and Queries of Prospective Bidders	PGCB's Reply/Clarification	Addendum (Yes-Y/No-N)
1.	If any tower needs to be dismantle then we understand that the foundation will not needed to be uprooted.	Contractor Shall have to cut the stubs from the top of pile cap and entire chimney is to be dismantled.	N
2.	<u>Section 8: Special Conditions of Contract : A new Clause 9.11 is added</u> <i>The Employer shall also monitor Contractor's activity concerning the implementation of the Resettlement Plan, secure necessary budget, pay actual compensation cost and ensure timely disbursement of compensation and other entitlements to the Project Affected Entities via the Contractor, Social Safeguard Consultants, and its Environmental and Social Unit following the provisions of the RP and the Development Project Proposal (DPP) as updated from time to time.</i> We understand that any type of compensation against Resettlement plan on the complete transmission line route will be paid by client. Only crop and tree compensation will be paid by contractor. Kindly confirm.	Payment of compensation for using private land to construct transmission line towers [based on area of tower footprint] and Payment of compensation for lines (for affected trees, crops etc. on the Right of Way and at the substation ends) both will be paid by the employer as per the bidding document. See Item no 7.12 and 7.13 of Price schedules (1.4, 2.4, 3.4 and 4.4). Also, please refer to the clarification-1, sl. No. 30.	N



Sl. No.	Reference and Queries of Prospective Bidders	PGCB's Reply/Clarification	Addendum (Yes-Y/No-N)
3.	<u>Price Schedule, Schedule No.1.4, 2.4, 3.4 & 4.4</u> SI. 7.12 Payment of compensation for using private land to construct transmission line towers [based on area of tower footprint] SI. 7.13 Payment of compensation for lines (for affected trees, crops etc. on the Right of Way and at the substation ends) The cost for above are particulars/compensation provided by you in Lump sum in Schedule No.1.4, Schedule No.2.4, Schedule No.3.4 & Schedule No.4.4. Kindly confirm these costs are fixed / ceiling and will be included in total price for evaluation only. The payment related to Right of Way / Compensation etc. shall be paid at actual upon submission of relevant documents.	Your understanding is not correct, these price shall be included in the contract price. Also, please refer to the Clarification-1, Sl. No.-12.	N
4.	Foundation Design: Please provide Foundation Over Load factor for 2T Tower.	Over Load factor for Foundation for 2T Tower Type is 1.35	N