

POWER GRID BANGLADESH PLC

Bidding Document

For

Procurement of

Design, Supply, Installation, Testing & Commissioning of 132/33 kV AIS Substations at Dhupchanchia, Kumarkhali, Matlab North and Chatkhil including associated 132KV bay extension at Kachua Substation on turnkey basis (Package-4)

(OCB NO. POWERGRID/ADB/PTSIREP/Package-4)

Addendum No. 03

(Date: July 15, 2026)

Following revisions/changes are made in the Bidding Document which will form part of the Bidding Document. The following changes/revisions are made in the Bidding Document, which shall form part of the Bidding Document:

Volume 3 of 3

Schedule E (TECHNICAL PARTICULARS AND GUARANTEES - GTP) Part 2:

1. Whatever mentioned in the GTP and other part of the tender document for 50/75 MVA and 80/120 MVA Transformer bidders are requested to follow the parameter as specified below:

Sl No.	For 50/75 MVA 132/33 kV Transformer		For 80/120 MVA 132/33 kV Transformer	
	Item in GTP (2.3) Sl. No.	Minimum Requirements	Item in GTP (2.4) Sl. No.	Minimum Requirements
01.	63	650 kV	5.1.8	1250A
02.	64	275 kV	3.2.1	50K
03.	65	132KV- 5075 33KV - 1256	3.2.3	55K