

POWER GRID BANGLADESH PLC

Bidding Document

For

Procurement of

Design, Supply, Installation, Testing & Commissioning of 132/33 kV AIS Substations at Dhupchanchia, Kumarkhali, Matlab North and Chatkhil including associated 132KV bay extension at Kachua Substation on turnkey basis (Package-4)

(OCB NO. POWERGRID/ADB/PTSIREP/Package-4)

Addendum No. 01

(Date: June __, 2026)

Following revisions/changes are made in the Bidding Document which will form part of the Bidding Document. The following changes/revisions are made in the Bidding Document, which shall form part of the Bidding Document:

Volume 1 of 3

1. Section 8 : Special Conditions of Contract Page 8-4

The following text-


“The Employer shall give administrative support to accord all rights of access for transmission line thereto on or before the date(s) specified in that appendix at the cost of the Contractor. Such cost is deemed to be included in the Contract Price. The Contractor shall be responsible for acquiring and providing physical possession of the transmission line sites and access thereto, and for acquiring possession of and access to all other areas reasonably required for the proper execution of the contract, as specified in the appendix (scope of works and supply by the employer) to the contract agreement.”

Shall be replaced as-

“The Employer shall give administrative support to accord all rights of access for substation thereto on or before the date(s) specified in that appendix at the cost of the Contractor. Such cost is deemed to be included in the contract price. The Contractor shall be responsible for acquiring and providing legal and

Addendum-1

OCB NO. POWERGRID/ADB/PTSIREP/Package-4



Page 1 of 4

physical possession of the substation sites and access thereto, and for acquiring possession of and access to all other areas reasonably required for the proper execution of the contract, as specified in the appendix (scope of works and supply by the employer) to the contract agreement.”

2. Price Schedule:

i) Description, unit and quantity of the following Items are corrected in the Schedule-1, 2 and 4 of price schedule and attached as attachment 1:

Schedule 1: 1E2, 2E2, 3E2, 4E2

Schedule 2: 1E2, 2E2, 3E2, 4E2

Schedule 4: 1E2, 2E2, 3E2, 4E2, 5K.7(i), 5K.8(i,ii,iii,iv)

Volume 2 of 3

1. Section 18: Drawings

The following documents/drawings have been revised/added and attached as attachment 2:

- i) The List of bid drawings has been revised (Revised page 18/1, 18/2)
- ii) Layout of Kachua substation has been revised (Drawing no: PG/ADB/Lay_all, Sheet 5 of 5)
- iii) Drawing of Slope (1V:2H) Protection with CC blocks has been added (Drawing no: PG/ADB/slope)
- iv) Boundary co-ordinates of four new substations have been added (Drawing no: PG/ADB/co-ordinates)

Saikat *Sujas* *[Signature]* *[Signature]*

[Signature]

[Signature]

[Signature]

[Signature]

v) 132 kV Double Circuit Tower Drawings/documents are included in the CD. These drawings are already approved and to be considered part of this bidding document. (Drawing no: PG/ADB/Tower)

Volume 3 of 3

1. Schedule A: INTRODUCTION & PREAMBLE TO THE PRICE & TECHNICAL SCHEDULES

i) Following items are corrected and attached as attachment 3:

In the "DESCRIPTION OF WORK 1,2,3,4" of all new four substation in the paragraph headed "33kV Air Insulated Switches and Connection", the text "The auxiliary transformer shall be connected to the LV side of two new 132/33kV three phase transformers." shall be replaced by the following text:

"The auxiliary transformer shall be connected to the 33 kV bus by a disconnect switch with integrated dropout fuse."

v) Following items are corrected and attached as attachment 4:

- | | |
|------------------------------|------------------------------|
| a) 1E2 (Revised Page- SA-17) | b) 2E2 (Revised Page- SA-27) |
| c) 3E2 (Revised Page SA-38) | d) 4E2 (Revised Page SA-48) |

2. Schedule E - Guaranteed Technical particulars

Santhosh

Sigra

[Signature]

[Signature]

[Signature]

[Signature]

i) The GTP of "2.5 - 33/0.415 kV EARTHING/AUXILIARY TRANSFORMERS" is corrected and attached as **attachment 5** (Revised page SE-120 & SE 123).

3. **Schedule D- MANUFACTURERS, PLACES OF MANUFACTURE** is revised and attached as **attachment 6** (Revised page SD-3).

Signe Salvin

